



Date: Tuesday, March 23, 2021

Addendum #: 1

Project Name: Electric Vehicle Charging Stations - Installation

Bid Due Date: Friday, March 26, 2021 at 10:00AM EST

This addendum will answer any questions/clarifications submitted after the mandatory pre-bid meeting held on Friday, March 19, 2021. A second bid addendum will be released for any additional questions received by the deadline for questions (Wednesday, March 24, 2021 at 10:00AM EST) for receiving all questions/clarifications as stipulated in the RFP.

1. Is there a brand preference on the panels?

There is no preference on the brand of the panel but they must be outdoor rated, and the actual meter base will be supplied by TCL&P.

2. How many spaces are needed in the panels if future spacing is needed for expansion?

At this point we are not concerned with future expansion. If the panels have extra space we would accept it, but it is not required for this bid.

3. Are 200A meters being installed?

a. The 2 – dual port Level II chargers (IQ200) would have a 400A meter. Each dual port charger requires 2 – 100A breakers.

i. That would mean a 4 individual 100A breakers for each location.

b. The 2 – DC Fast chargers (RTM75) would have a 400A meter.

c. The 1 – DC Fast charger (RTM75) would have a 200A meter.